

## **EXHIBIT 2**



# **CERTIFICATE OF COMPLIANCE**

## **FOR**

**Ameridose**  
**Framingham, MA 01702**

### **Clean Room**

The above referenced clean zone has successfully passed the minimum requirements for an ISO Class 6 clean zone per the requirements of ISO Standards 14644-1:1999 and 14644-2:2000 for particle count testing of Cleanrooms and associated controlled environments. This clean zone was tested in the At Rest occupancy state at 0.5 micrometers and larger particle sizes. Testing was performed as outlined in ISO Standards 14644-1:1999, 14644-2:2000 and 14644-3:2005. The classification is applicable to the above clean zone designated in the report prepared August 2006.

Date of Certification: July 12, 2006

Due for Retest: July-2007

Certified By: Charles Kuchinsky / Mike Lombard

Approval: CENV200608023



2880 Bergey Rd. - Suite K - Hatfield, PA 19440-1764 - 800-345-6094

ISO 14644-1:1999

CONFIDENTIAL PROTECTED 003669



# **CERTIFICATE OF COMPLIANCE**

## **FOR**

**Ameridose**  
**Framingham, MA 01702**

### **People's Ante Room**

The above referenced clean zone has successfully passed the minimum requirements for an ISO Class 6 clean zone per the requirements of ISO Standards 14644-1:1999 and 14644-2:2000 for particle count testing of Cleanrooms and associated controlled environments.

This clean zone was tested in the At Rest occupancy state at 0.5 micrometers and larger particle sizes. Testing was performed as outlined in ISO Standards 14644-1:1999, 14644-2:2000 and 14644-3:2005. The classification is applicable to the above clean zone designated in the report prepared August 2006.

Date of Certification: July 12, 2006

Due for Retest: July-2007

Certified By: Charles Kuchinsky / Mike Lombard

Approval: CENV200608023

RC-ADM-0280.001

2880 Bergey Rd. - Suite K - Hatfield, PA 19440-1764 - 800-345-6094

CONFIDENTIAL PROTECTED 003670



# ***CERTIFICATE OF COMPLIANCE***

## ***FOR***

**Ameridose  
Framingham, MA 01702**

### **Prep Room**

The above referenced clean zone has successfully passed the minimum requirements for an ISO Class 7 clean zone per the requirements of ISO Standards 14644-1:1999 and 14644-2:2000 for particle count testing of Cleanrooms and associated controlled environments.

This clean zone was tested in the At Rest occupancy state at 0.5 micrometers and larger particle sizes. Testing was performed as outlined in ISO Standards 14644-1:1999, 14644-2:2000 and 14644-3:2005. The classification is applicable to the above clean zone designated in the report prepared August 2006.

Date of Certification: July 12, 2006

Due for Retest: July-2007

Certified By: Charles Kuchinsky / Mike Lombard

Approval: CENV200608023

RC-ADM-0238.001

2880 Bergey Rd. - Suite K - Hatfield, PA 19440-1764 - 800-345-6094

CONFIDENTIAL PROTECTED 003671



# ***CERTIFICATE OF COMPLIANCE***

## ***FOR***

**Ameridose  
Framingham, MA 01702**

### **Freight Ante Room**

The above referenced clean zone has successfully passed the minimum requirements for an ISO Class 8 clean zone per the requirements of ISO Standards 14644-1:1999 and 14644-2:2000 for particle count testing of Cleanrooms and associated controlled environments.

This clean zone was tested in the At Rest occupancy state at 0.5 micrometers and larger particle sizes. Testing was performed as outlined in ISO Standards 14644-1:1999, 14644-2:2000 and 14644-3:2005. The classification is applicable to the above clean zone designated in the report prepared August 2006.

Date of Certification: July 12, 2006

Due for Retest: July-2007

Certified By: Charles Kuchinsky / Mike Lombard

Approval: CENV200608023

RC-ADM-0280.001

2880 Bergey Rd. - Suite K - Hatfield, PA 19440-1764 - 800-345-6094

CONFIDENTIAL PROTECTED 003672